

Operation of BEST ECG compatibility T8 LED tube
 Compatibility list: tested ballasts for use with ECG.

ECGsmart T8 5ft
 Replace 58W T8

Manufacturer	Model	Replace target fluorescent T8	Number of Lamps
Philips	HF-E 1/2 58 TL-D II	58W	1
Philips	HF-E 1/2 58 TL-D II	58W	2
Philips	HF-B 158 TLD 220-240	58W	1
Philips	HF-B 258 TLD 220-240	58W	2
Philips	HF-B 258 TL-D EII 220-240	58W	2
Philips	HF-B 158 TLD EII 220-240	58W	1
Philips	HF-P 158 TLD EII 220-240	58W	1
Philips	HF-P 258 TLD EII 220-240	58W	2
Philips	HF-P 158 TLD 220-240	58W	1
Philips	HF-P 258 TLD 220-240	58W	2
Philips	HF-S 158 TL-D II	58W	1
Philips	HF-S 258 TL-D II	58W	2
OSRAM	QT-FIT8 1x58	58W	1
OSRAM	QT-FIT8 2x58	58W	2
OSRAM	QTP8 1x58	58W	1
OSRAM	QTP8 2x58	58W	2
OSRAM	QTP-OPTIMAL 1x54-58	58W	1
OSRAM	QTP-OPTIMAL 2x54-58	58W	2
OSRAM	Qti 1x28/54/35/49 GII	58W	1*
OSRAM	Qti 2x28/54/35/49 GII	58W	2*
OSRAM	QT-FIT 5/8 1x54-58	58W	1
OSRAM	QT-FIT 5/8 2x54-58	58W	2
OSRAM	QTi DALI 2x58 DIM	58W	2*
OSRAM	QTi DALI 1x58 DIM	58W	1*
TRIDONIC	PC 1x58 T8 PRO lp	58W	1
TRIDONIC	PC 1x58 T8 TOP sl	58W	1
TRIDONIC	PC 2/58 T8 PRO	58W	2
TRIDONIC	PC 2x58 T8 TOP sl	58W	2
TRIDONIC	PC 2/14-35/49/54 T5 PRO-M lp	58W	2*
HELVAR	EL1X58HF	58W	1
HELVAR	EL2X58ES	58W	2
STAHL	6042/963-21	58W	1
STAHL	6042/963-22	58W	2
VS	ELXC 158.218	58W	1
VS	ELXC 158.201	58W	1
VS	ELXC 258.210	58W	2
VS	ELXC 258.219	58W	2
VS	ELXC 258.203	58W	2
BAG	D58.1-2302E	58W	1
BAG	BCS 58.1FX-11/220-240	58W	1
BAG	BCS 58.1SR-01/220-240	58W	1

BAG	SCS58.2SR-11/220-240	58W	2
Vossloh	ELXc 258.219	58W	2
Vossloh	ELXc 258.219	58W	2
ABB	EVG 1X58 CF	58W	1
ABB	EVG 2X58 CF ABB	58W	2

The compatibility list is based upon testing conducted by the manufacturer in a lab simulated environment, and the results can vary in certain field applications due to a number of factors.

Benson Energy Saving Technology does not take over any responsibility, warranty or liability that this results can also achieved by using the devices under other conditions, or when using successor models of the tested devices, or different models of the same manufacturer, or when using other LED tube types. The absence of a ballast from this chart does not necessarily imply incompatibility.

* Can only working with ECGsmart Series LED tubes

1-Jun-23
updated